

<u>Building Division</u>: 408-615-2440 Email: Building@santaclaraca.gov <u>Permit Center</u>: 408-615-2420 Email: PermitCenter@santaclaraca.gov

Automated Inspection Scheduling System: 408-615-2400

EXPEDITED SOLAR PHOTOVOLTAIC PERMITTING FOR ONE- AND TWO-FAMILY DWELLINGS – CENTRAL STRING INVERTER SYSTEM

This guide is for a streamlined permitting process for solar photovoltaic (PV) projects 10 kW in size or smaller, and includes information about submittal requirements for plan review, required fees and inspections.

1. Approval Requirements

- a) Planning department approval is required.
- b) A building permit is required.
- c) An electrical permit is required.
- d) A fire department permit is not required.
- e) Silicon Valley Power approval is required.

2. Submittal Requirements

- a) Completed permit application form. This permit application form can be downloaded at http://santaclaraca.gov/government/departments/community-development.
- b) Demonstrate compliance with the eligibility checklist for expedited permitting.
- c) A completed Standard Electrical Plan. The standard plan may be used for proposed solar installations 10 kW in size or smaller. This will include:
 - Locations of main service or utility disconnect
 - Total number of modules, number of modules per string and the total number of strings
 - Make and model of inverter(s) and/or combiner box if used
 - One-line diagram of system
 - Specify grounding/bonding, conductor type and size, conduit type and size and number of conductors in each section of conduit
 - Equipment cut sheets including inverters, modules, AC and DC disconnects, combiners and racking system.
 - Labeling of equipment as required by CEC, Sections 690 and 705
 - Site diagram showing the arrangement of panels on the roof or ground, north arrow, lot dimensions and the distance from property lines to adjacent buildings/structures (existing and proposed)
- d) A roof plan showing roof layout, PV panels and the following fire safety items: approximate location of roof access point, location of code-compliant access pathways, PV system fire classification and the locations of all required labels and markings. Examples of clear path access pathways are available in the State Fire Marshal Solar PV Installation Guide. http://osfm.fire.ca.gov/pdf/reports/solarphotovoltaicguideline.pdf.
- e) Complete expedited Structural Criteria along with required documentation.

For non-qualifying systems, provide structural drawings and calculations stamped and signed by a Californialicensed Civil or Structural Engineer, along with the following information.

- The type of roof covering and the number of roof coverings installed
- Type of roof framing, size of members and spacing
- Weight of panels, support locations and method of attachment
- Framing plan and details for any work necessary to strengthen the existing roof structure
- Site-specific structural calculations
- Provide manufacturer documentation of the rack system, maximum allowable weight the system can support, attachment methods, and product evaluation information or structural design.

3. Plan Review

Permit applications can be submitted to the Building Division, City of Santa Clara Community Development Department, in person at 1500 Warburton Ave, Santa Clara, CA 95050. Permit applications utilizing the standard plan may be approved "over the counter." Permits not approved "over the counter" will be reviewed in one to fifteen business days. Permits submitted online cannot be an expedited review.

4. Fees

See current **Building Fee Schedule**.

5. Inspections

Once all permits to construct the solar installation have been issued and the system has been installed, it must be inspected before final approval is granted for the solar system. On-site inspections can be scheduled by contacting the building division by our automated telephone system (408) 615-2400. Inspection requests are scheduled on a first-come first-served basis. If there is no other related work on the permit (such as a service upgrade) the first scheduled inspection can be the building and electrical final – menu codes 599 and 299 on the automated system.

Compliance with current smoke and carbon-monoxide alarm requirements is mandatory for all building permits.

Permit holders must be prepared to show conformance with all technical requirements in the field at the time of inspection. The inspector will verify that the installation is in conformance with applicable code requirements and with the approved plans.

The inspection checklist provides an overview of common points of inspection for which applicant should be prepared to show compliance. If not available, common checks include the following.

- Number of PV modules and model number match plans and specification sheets number match plans and specification sheets.
- Array conductors and components are installed in a neat and workman-like manner.
- PV array is properly grounded.
- Electrical boxes are accessible, and connections are suitable for environment.
- Array is fastened and sealed according to attachment detail.
- Conductors ratings and sizes match plans.
- Appropriate signs are properly constructed, installed and displayed, including the following.
 - Sign identifying PV power source system attributes at DC disconnect
 - Sign identifying AC point of connection
 - Sign identifying switch for alternative power system
- Equipment ratings are consistent with application and installed signs on the installation, including the following.
 - Inverter has a rating as high as max voltage on PV power source sign.
 - DC-side overcurrent circuit protection devices (OCPDs) are DC rated at least as high as max voltage on sign.
 - Switches and OCPDs are installed according to the manufacturer's specifications (i.e., many 600VDC switches require passing through the switch poles twice in a specific way).
 - Inverter is rated for the site AC voltage supplied and shown on the AC point of connection sign.
 - OCPD connected to the AC output of the inverter is rated at least 125% of maximum current on sign and is no larger than the maximum OCPD on the inverter listing label.
 - Sum of the main OCPD and the inverter OCPD is rated for not more than 120% of the bus bar rating.



<u>Building Division</u>: 408-615-2440 Email: Building@santaclaraca.gov <u>Permit Center</u>: 408-615-2420 Email: PermitCenter@santaclaraca.gov

Automated Inspection Scheduling System: 408-615-2400

ELIGIBILITY CHECKLIST FOR EXPEDITED SOLAR PHOTOVOLTAIC PERMITTING FOR ONE- AND TWO-FAMILY DWELLINGS

GENERAL REQUIREMENTS

A. B. C. D. E.	System size is 10 kW AC CEC rating or less The solar array is roof-mounted on one- or two-family dwelling or accessory structure The solar panel/module arrays will not exceed the maximum legal building height Solar system is utility interactive and without battery storage Permit application is completed and attached	 Y Y Y Y Y Y 		1 1 1
ELE	CTRICAL REQUIREMENTS			
A.	No more than four photovoltaic module strings are connected to each Maximum Power Point Tracking (MPPT) input where source circuit fusing is included in the inverter	□ Y	□ N	I
	1) No more than two strings per MPPT input where source circuit fusing is not included	ΠY		•
	2) Fuses (if needed) are rated to the series fuse rating of the PV module3) No more than one non-inverter integrated DC combiner is utilized per inverter			
В.	For central inverter systems: No more than two inverters are utilized			•
С.	The PV system is interconnected to a single-phase AC service panel of nominal			
	120/220 Vac with a bus bar rating of 225 A or less	🗆 Y		1
D.	The PV system is connected to the load side of the utility distribution equipment	Ο Υ	🗆 N	I
Ε.	A Solar PV Standard Plan and supporting documentation is completed and attached	🗆 Y		I
STR	RUCTURAL REQUIREMENTS			
A.	A completed Structural Criteria and supporting documentation is attached (next page)	□ Y	□ N	I
FIR	E SAFETY REQUIREMENTS			
А. В.	Clear access pathways provided Fire classification solar system is provided	□ Y □ Y		-
C. D.	All required markings and labels are provided A diagram of the roof layout of all panels, modules, clear access pathways and	□ Y	□ N	1
	approximate locations of electrical disconnecting means and roof access points is completed and attached	D Y		1

Notes:

- 1. These criteria are intended for expedited solar permitting process.
- 2. If any items are checked NO, revise design to fit within Eligibility Checklist, otherwise permit application may go through standard process.

Eligibility Checklist – Structural Criteria for Residential Flush-Mounted Solar Arrays

1. ROOF CHECKS		
 A. Visual Review/Contractor's Site Audit of Existing Conditions: 1) Is the roof a single roof without a reroof overlay? 2) Does the roof structure appear structurally sound, without signs of alterations 	□ Y	🗆 N
or significant structural deterioration or sagging, as illustrated in Figure 1? B. Roof Structure Data:	🗆 Y	🗆 N
1) Measured roof slope (e.g. 6:12):		:12
2) Measured rafter spacing (center-to-center):		inch
3) Type of roof framing (rafter or manufactured truss):	Rafter I	Truss
2. SOLAR ARRAY CHECKS		
A. Flush-mounted Solar Array:		
1) Is the plane of the modules (panels) parallel to the plane of the roof?	🗆 Y	🗆 N
2) Is there a 2" to 10" gap between underside of module and the roof surface?	🗆 Y	🗆 N
3) Modules do not overhang any roof edges (ridges, hips, gable ends, eaves)?	🗆 Y	🗆 N
B. Do the modules plus support components weigh no more than:		
4 psf for photovoltaic arrays or 5 psf for solar thermal arrays?	🗆 Y	🗆 N
C. Does the array cover no more than half of the total roof area (all roof planes)?	🗆 Y	🗆 N
D. Are solar support component manufacturer's project-specific completed worksheets,		
tables with relevant cells circled, or web-based calculator results attached?	🗆 Y	🗆 N
E. Is a roof plan of the module and anchor layout attached? (see samples & last page) F. Downward Load Check (Anchor Layout Check):	□ Y	🗆 N
1) Proposed anchor horizontal spacing:	,_	"(ft-in)
2) Manufacturer specification for anchor	,	(ft-in)
spacing:		(it-iii)
G.Wind Uplift Check (Anchor Fastener Check):		
1) Anchor fastener data (provide cut sheets):		
a. Diameter of lag screw, hanger bolt or self-drilling screw:		inch
b. Embedment depth of rafter:		inch
c. Number of screws per anchor (typically one):		
d. Are 5/16" diameter lag screws embedded 2.5" into the rafters		
or does the anchor fastener have a different manufacturer specification?	□ ү	ΠN
3. SUMMARY		

A. All items above are checked YES. No additional calculations are required.

□ B. One or more items are checked NO. Attach project-specific drawings and calculations stamped and signed by a California-licensed civil or structural engineer.

Job Address:		Permit #:
Contractor/Installer:		_License # & Class:
Signature:	Date:	_Phone #:



<u>Building Division</u>: 408-615-2440 Email: Building@santaclaraca.gov <u>Permit Center</u>: 408-615-2420 Email: PermitCenter@santaclaraca.gov

Automated Inspection Scheduling System: 408-615-2400

SOLAR PV STANDARD PLAN – SIMPLIFIED CENTRAL/STRING INVERTER SYSTEMS FOR ONE- AND TWO-FAMILY DWELLINGS

SCOPE: Use this plan ONLY for electrical review of utility central/string inverter systems not exceeding a system AC inverter output rating of 10kW on the roof of a one- or two-family dwelling or accessory building. The specific structural and fire requirements are covered in other parts of the California Solar Permitting Guidebook. The photovoltaic system must interconnect to the load side of a single-phase AC service panel of nominal 120/240Vac with a bus bar rating of 225A or less. This plan is not intended for bipolar systems, hybrid systems or systems that utilize storage batteries, charge controllers, trackers, more than two inverters or more than one DC combiner (noninverter-integrated) per inverter. Systems must be in compliance with current California Building Standards Codes and local amendments of the authority having jurisdiction (AHJ). Other Articles of the California Electrical Code (CEC) shall apply as specified in 690.3. For systems beyond this scope or the criteria in this plan, consult the AHJ for details regarding comprehensive process.

MANUFACTURER'S SPECIFICATION SHEETS MUST BE PROVIDED for proposed inverters, modules, combiner/junction boxes, racking systems, and rapid shutdown system or equipment. Installation instructions for bonding and grounding equipment and rapid shutdown systems shall be provided, and local AHJs may require additional details. Listed and labeled equipment shall be installed and used in accordance with any instructions included in the listing or labeling [CEC 110.3]. Equipment intended for use with PV system shall be listed for the PV application [CEC 690.4(B)].

Job Address:		Permit #:
Contractor/Engineer Name:		License # and Class:
Signature:	Date:	Phone Number:
Total # of Inverters installed:	(If more than o	ne inverter, complete and attach the "Supplemental

Calculation Sheets" and the "Load Center Calculations" if a new load center is to be used.)

Inverter 1 AC Output Power Rating:______Watts

Inverter 2 AC Output Power Rating (if applicable):______ Watts

Combined Inverter Output Power Rating:_____≤ 10,000 Watts

Location Ambient Temperatures (Check box next to which lowest expected temperature is used):

1) Lowest expected ambient temperature for the location (T_L) = Between -1° to -5° C

□ Lowest expected ambient temperature for the location (T_L) = **Between -6° to -10° C**

Average ambient high temperature $(T_H) = 47^{\circ} C$

Note: For a lower T_L or a higher T_H , use the Comprehensive Standard Plan

DC Information:

Module Manufacturer:	Model:
2) Module V _{oc} (from module nameplate):Volts	3) Module I _{sc} (from module nameplate):Amps
4) Module DC output power under standard test condi	tions (STC) =Watts (STC)

5) DC Module Layout																	
Identify each source circuit (string) for inverter 1 shown on the roof plan with a Tag (e.g. A,B,C,)	erter 1 shown an with a Tag Number of modules per					Identify, by tag, which source circuits on the roof are to be paralleled (if none, put N/A)											
						Cor	nbine	er 1:									
						_											
						Combiner 2:											
Total number of source circuits	for inver	ter 1:															
6) Are DC/DC Converters	used?	□ Y	'es		10	If N	o, ski	p to	Step	7. If	Yes er	nter i	nfo b	elow	/.		
DC/DC Converter Model #:						D	C/DC	Conv	erter l	Max D	C Input	: Volta	ge:		Volt	5	
Max DC Output Current:			A	mps		N	lax DC	Out	put Cu	irrent:					_Volt	5	
Max # of DC/DC Converters in	an Input	Circuit	:			D	C/DC	Conv	erter l	Max D	C Input	Powe	r:		Watts		
7) Maximum System DC \	7) Maximum System DC Voltage — Use A1 or A2 for systems without DC/DC converters, and B1 or B2 with DC/DC Converters.																
□ A1. Module V _{oc} (STEP 2) =_		x#	in ser	ries (S	TEP 5)			x 1	12 (If	-1 ≤ T ₁	≤-5°C,	STEP	1) =			_V	
A2. Module V_{oc} (STEP 2) =		x #	in ser	ries (S	TEP 5)	5)x 1.14 (If -6 ≤ T _L ≤ -10°C, STEP 1) =V											
Table 1. Maximum Numbe	r of PV N	lodules	in Ser	ries Ba	ased o	n Moo	lule Ra	ated \	√ _{oc} for	600 V	dc Rate	d Equi	pmen	t (CEC	690.7	7)	
Max. Rated Module V _{oc} (*1.1 (Vol		31.5	1 33.	.48	35.71	38.27	41.2	21 4	4.64	48.70	53.57	59.52	2 66.	96 7	6.53	89.29	
Max. Rated Module V _{oc} (*1.1 (Vol		30.9	6 32.	.89 3	35.09	37.59	40.4	19 4	3.86	47.85	52.63	58.48	3 65.	79 7	5.19	87.72	
Max # of Modules for 600 V	lc 18	17	1	.6	15	14	13		12	11	10	9	8		7	6	
Use for DC/DC converters. The v	alue calc	ulated b	below	must	be les	s than	DC/DC	Conv	verter	max D	C input	voltag	e (STE	P 6).			
□ B1. Module V _{oc} (STEP 2) =	×	# of m	odules	s per	convei	rter (S	ΓEP 6)_		x 1	.12 (If	-1≤T _L ≤	≤ -5°C,	STEP :	L) =		_V	
B2. Module V_{oc} (STEP 2) =	×	# of m	odules	s per	convei	rter (S	FEP 6)_		x 1	.14 (If	-6 ≤ T _L :	≤-10°C	C, STEP	1) =_		_V	
Table 2. Largest Module V _o	for Single	e-Modu	ile DC	/DC C	Conver	ter Co	nfigura	ation	s (witł	1 80 V <i>i</i>	AFCI Ca	ıp) (CE	C 690.	7 and	690.1	1)	
Max. Rated Module V _{oc} (*1.1 (Vol	. 30.4	33.0	35.7	38.4	41.1	43.8	46.4	49.1	51.8	3 54.5	57.1	59.8	62.5	65.2	67.9	70.5	
Max. Rated Module V _{oc} (*1.1 (Vol		32.5	35.1	37.7	40.4	43.0	45.6	48.2	50.9	9 53.5	56.1	58.8	61.4	64.0	66.7	69.3	
	DC/DC Converter Max DC Input (Step #6) (Volts) 34 37 40 43 46 49 52 55 58 61 64 67 70 73 76 79							79									
8) Maximum System DC Voltage from DC/DC Converters to Inverter — Only required if Yes in Step 6 Maximum System DC Voltage =Volts																	

 9) Sizing Source Circuit Conductors Source Circuit Conductor Size = Min. #10 AWG copper conductor, 90° C wet (USE-2, PV Wire, XHHW-2, THWN-2, RHW-2) For up to 8 conductors in roof-mounted conduit exposed to sunlight at least ½" from the roof covering [CEC 310] Note: If > 8 conductors in the conduit or mounting height of lower than ½" from the roof, expedited plan not applicable.
 10) Are PV source circuits combined prior to the inverter? □ Yes □ No If No, use Single Line Diagram 1 and proceed to Step 13. If Yes, use Single Line Diagram 2 with Single Line Diagram 4 and proceed to Step 12. Is source circuit OCPD required? □ Yes □ No Source circuit OCPD size (if needed):
11) Sizing PV Output Circuit Conductors — If a combiner box will NOT be used (Step 10), Output Circuit Conductor Size =
12) Inverter DC Disconnect Does the inverter have an integrated DC disconnect?
13) Inverter Information Manufacturer: Model: Max. Continuous AC Output Current Rating:Amps Integrated DC Arc-Fault Circuit Protection?

AC Information:

) Sizing Inverter Output Circuit Conductors and OCPD Inverter Output OCPD rating =Amps (Table 3) Inverter Output Circuit Conductor Size =AWG (Table 3)									
Table 3. Minimum Inverter Output OCPD and Circuit Conductor Size									
Inverter Continuous Output Current Rating (Amps) (Step 14)	12	16	20	24	28	32	36	40	48
Minimum OCPD Size (Amps)	15	20	25	30	35	40	45	50	60
Minimum Conductor Size (AWG, 75° C, Copper)	14	12	10	10	8	8	6	6	6

15) Point of Connection to Utility

Only load side connections are permitted with this plan. Otherwise, use Comprehensive Standard Plan.

Is the PV OCPD positioned at the opposite end from input feeder location or main OCPD location? \Box Yes \Box No

If Yes, circle the Max Combined PV System OCPD(s) at 120% value as determined from Table 4.

If No, rating of main OCPD and Max Combined PV System OCPDs must be ≤ bus bar rating.

If the panel has a "center-fed" main, the same rule can be used as when the breaker is at the opposite end from the main, provided there are loads between the main and PV breakers. (pre-approved AMM per Building Standards Commission recommendation)

Table 4. Maximum Combined Supply OCPDs Based on Bus Bar Rating (Amps) per CEC 705.12(D)(2)										
Bus Bar Rating	100	125	125	200	200	200	225	225	225	
Main OCPD	100	100	125	150	175	200	175	200	225	
Max Combined PV System OCPD(s) at 120% of Bus Bar Rating	20	50	25	60*	60*	40	60*	60*	45	
Max Combined PV System OCPD(s) at 100% Bus Bar Rating	0	25	0	50	25	0	50	25	0	

*This value has been lowered to 60 A from the calculated value to reflect 10 kW AC size maximum.

Reduction of the main breaker is not permitted with this plan. Otherwise, use Comprehensive Standard Plan.

16) Rapid Shutdown₂

The rapid shutdown initiation device shall be labeled according to CEC 690.56(C), and its location shall be shown on the site plan drawing. The rapid shutdown initiation device may be the inverter output or input circuits' disconnecting means, the service main disconnect, or a separate device as approved by the AHJ. The disconnecting means shall be identified for the purpose, suitable for their environment, and listed as a disconnecting means. A single rapid shutdown initiation device shall operate all disconnecting means necessary to control conductors in compliance with CEC 690.12.

Note: Check with the AHJ regarding approval where field verification of reduction of voltage within the time required by CEC 690.12 is performed.

Rapid shutdown shall be provided as required by CEC 690.12 with one of the following methods (Select one):

- □ The inverter(s) is within 10 feet of the array, and the location of the inverter is such that uncontrolled PV system conductors are no greater than 5 feet of length within the building. A remotely-controlled AC disconnecting means is required immediately adjacent to or as close as practicable to the inverters, and located within 10 feet of the array.
- The inverter(s) is within 10 feet of the array, and the location of the inverter is such that uncontrolled PV system conductors are no greater than 5 feet of length within the building.
 Reduction of the voltage for the inverter output within the time required by CEC 690.12 shall be verified in the field, or the inverter output is listed to UL 1741 with rapid shutdown capability.
- Remotely-controlled DC disconnecting means are located within 10 feet of the PV array and DC input of the inverter(s), and the locations of the disconnecting means are such that uncontrolled PV system conductors are no greater than 5 feet of length within the building. Reduction of the voltage for the inverter output within the time required by CEC 690.12 shall be verified in the field, or the inverter output is listed to UL 1741 with rapid shutdown capability.
- Remotely-controlled DC disconnecting means is located within 10 feet of the array at the DC input of inverter(s) connected to a module level DC-DC converter circuit where the DC-DC converter circuit meets the requirements for controlled conductors when disconnected from the inverter. Reduction of the voltage for the DC-DC converter output and the inverter output within the time required by CEC 690.12 shall be verified in the field, or the DC-DC converter output and the inverter output are listed to UL 1741 with rapid shutdown capability.
- □ A UL 1741-listed and identified inverter(s) with input and output rapid shutdown capability supplying module level DC-DC converter circuit where the DC-DC converter circuit meets the requirements for controlled conductors when disconnected from the inverter.
- □ A UL 1741-listed rapid shutdown system:

Manufacturer:

Testing Agency Name: _____

System Model Number: _____


System Components: _____


17) Grounding and Bonding of Modules and Racking System (select one):

- □ Racking system listed to UL 2703 using modules identified in the listing.
- □ Other method subject to approval by City of Santa Clara

Markings


Labels are required by articles 690 and 705 of the CEC and R324 of the California Residential Code. Not all of these labels are required at each project. Provide a plan showing which labels go at each of the locations.






Informational note: ANSI Z535.4 provides guidelines for the design of safety signs and labels for application to products. A phenolicplaque with contrasting colors between the text and background would meet the intent of the code for permanency. No type size is specified, but 20 point (3/8") should be considered the minimum. CEC 705.12 requires a permanent plaque or directory denoting all electric power sources on or in the premises.

Solar PV Standard Plan – Simplified Central/String Inverter System for One- and Two-Family Dwellings Refer to Step 16 for Rapid Shutdown details



Solar PV Standard Plan – Simplified Central/String Inverter System for One- and Two-Family Dwellings Refer to Step 16 for Rapid Shutdown details



Supplemental Calculation Sheets for Inverter #2 (Only include if <u>second</u> inverter is used)

DC Information:

Module Manufacturer: Model:									
plate):Volts	S3) Module I _{sc} (from module nameplate):Amps								
S4) Module DC output power under standard test conditions (STC) =Watts (STC)									
ber of modules per circuit for inverter 1	Identify, by tag, which source circuits on the roof are to be paralleled (if none, put N/A)								
	Combiner 1:								
	-								
	Combiner 2:								
	-								
er 1:									
□ _{Yes} □ _{No}	If No, skip to Step S7. If Yes, enter info below.								
Amps Circuit:	DC/DC Converter Max DC Input Voltage:Volts Max DC Output Current:Volts DC/DC Converter Max DC Input Power:Watts								
	plate):Volts der standard test c ber of modules per circuit for inverter 1 er 1: Yes NoAmps								

S7) Maximum System DC Voltage — Use A1 or A2 for systems without DC/DC converters, and B1 or B2 with DC/DC Converters.														
A1. Module V_{oc} (STEP S2) = x # in series (STEP S5) x 1.12 (If $-1 \le T_L \le -5^{\circ}C$, STEP S1) = V								V						
A2. Module V_{oc} (STEP S2) = x # in series (STEP S5) x 1.14 (If $-6 \le T_L \le -10^{\circ}C$, STEP S1) = V						V								
Table 1. Maximum Number o	of PV Mo	odules i	n Series	Based	on Mod	ule Rat	ed V _{oc} f	or 600 V	dc Rate	d Equi	pment	t (CEC	690.7	')
Max. Rated Module V _{oc} (*1.12) (Volts)	29.76	31.51	33.48	35.71	38.27	41.21	44.64	48.70	53.57	59.52	66.9	96 7	6.53	89.29
Max. Rated Module V _{oc} (*1.14) (Volts)	29.24	30.96	32.89	35.09	37.59	40.49	43.86	47.85	52.63	58.48	65.3	79 7	5.19	87.72
Max # of Modules for 600 Vdc	18	17	16	15	14	13	12	11	10	9	8		7	6
Use for DC/DC converters. The valu	ie calcu	lated be	lowmu	ist be les	s than I	DC/DC	converte	er max D	C input	voltage	e (STEI	P S6).		
B1. Module V _{oc} (STEP S2) =	×	# of m	odules	oer conv	erter (S	TEP S6	1	x 1.12	(If -1 ≤]	Γ. ≤ -5°	C. STE	P S1):	=	V
B2 Module V., (STEP S2) =														
Table 2. Largest Module V _{oc} fo	r Single∙	-Module	e DC/D	C Conve	rter Cor	nfigurat	ions (w	ith 80 V	AFCI Ca	p) (CE	C 690.	7 and	690.1	1)
Max. Rated Module V _{oc} (*1.12) (Volts)	30.4	33.0 3	5.7 38	.4 41.1	43.8	46.4	49.1 5	1.8 54.	5 57.1	59.8	62.5	65.2	67.9	70.5
Max. Rated Module V _{oc} (*1.14) (Volts)	29.8	32.5 3	5.1 37	7.7 40.4	43.0	45.6	48.2 5	0.9 53.	5 56.1	58.8	61.4	64.0	66.7	69.3
DC/DC Converter Max DC Input (Step 6) (Volts)	34	37	40 4	3 46	49	52	55 5	61 61	64	67	70	73	76	79
S8) Maximum System DC V	-						verter	— On	ly req	uired	if Yes	s in S	tep S	6
Maximum System DC Voltage =Volts														
	S9) Maximum Source Circuit Current													
Is Module I _{sc} below 9.6	Is Module I _{sc} below 9.6 Amps (Step S3)? 🛛 Yes 🔤 No (If No, use Comprehensive Standard Plan)													
S10) Sizing Source Circuit Co	nduct	ors												
Source Circuit Conductor			10 AW	G copp	er con	ducto	r, 90° (Cwet (I	JSE-2,	PV Wi	re, Xl	HHW	-2,	
THWN-2, RHW-2)														
For up to 8 conductors in r						-						-		
Note: For over 8 conductor Plan.	S III LIII	conut		Iountin	g neigi		wertin	dii /2 ii		21001,	use c	,omp	enen	Sive
S11) Are PV source circuits c						?	Yes)					
If No, use Single Line Diag				•		ram 1	and n	racaa	4 + 0 6 +	00 61	r			
If Yes, use Single Line Di Is source circuit	-		-	-	-		anu p	TOLEE	1 10 51	ep 51	.2.			
Source circuit O														
	S12) Sizing PV Output Circuit Conductors — If a combiner box will NOT be used (Step S11), Output Circuit Conductor Size = Min. #6 AWG copper conductor													
S13) Inverter DC Disconnect														
Does the inverter have ar	n integ	rated I	DC dis	connec	t? 🗖	Yes	n No	If Ye	s, proc	eed to	o Step	S14		
	Does the inverter have an integrated DC disconnect? If No, the external DC disconnect to be installed is rated for Amps (DC) and Volts (DC)													

verter Information
anufacturer: Model:
ax. Continuous AC Output Current Rating: Amps
egrated DC Arc-Fault Circuit Protection?
ounded or Ungrounded System? 🗖 Grounded 🗖 Ungrounded


AC Information:

S15) Sizing Inverter Output Circuit Conductors and Inverter Output OCPD rating =Amps (Tal Inverter Output Circuit Conductor Size =A	ble 3)								
Table 3. Minimum Inverter Output OCPD and Circuit Conductor Size									
Inverter Continuous Output Current Rating (Amps) (Step 14)	12	16	20	24	28	32	36	40	48
Minimum OCPD Size (Amps)	15	20	25	30	35	40	45	50	60
Minimum Conductor Size (AWG, 75° C, Copper)	14	12	10	10	8	8	6	6	6


Load Center Calculations (Omit if a load center will not be installed for PV OCPDs)

S20) Load Center Output: Calculate the sum of the maximum AC outputs from each inverter.		
Inverter #1 Max Continuous AC Output Current Rating [STEP S14]	× 1.25 =	Amps
Inverter #2 Max Continuous AC Output Current Rating [STEP S14]	<u> </u>	Amps
Total inverter currents connected to load center (sum of above)	=	Amps
Conductor Size:AWG Overcurrent Protection Device:Amps Load center bus bar rating:Amps The sum of the ampere ratings of overcurrent devices in circuits supply shall not exceed 120 percent of the rating of the bus bar or condu		bar or conductor

Solar PV Standard Plan – Simplified Central/String Inverter System for One- and Two-Family Dwellings



Solar PV Standard Plan – Simplified Central/String Inverter System for One- and Two-Family Dwellings



SOLAR PV STANDARD PLAN

Roof Layout Diagram for One- and Two-Family Dwellings

Items required: roof layout of all panels, modules, clear access pathways and approximate locations of electrical disconnecting means and roof access points.