



City of Santa Clara

The Center of What's Possible

Building Division: 408-615-2440
 Email: Building@santaclaraca.gov
 Permit Center: 408-615-2420
 Email: PermitCenter@santaclaraca.gov
 Automated Inspection Scheduling System: 408-615-2400

2022 CALIFORNIA GREEN BUILDING CODE (CGC) CHECKLIST FOR ADDITIONS OR ALTERATIONS TO (E) NONRESIDENTIAL BUILDINGS

Building additions of 1,000 square feet or greater AND/OR building alterations with a permit valuation of \$200,000 or more shall be designed to include the green building measures specified as mandatory in the application checklists for additions or alterations.

BUILDING PERMIT NO.: BLD2
 ADDRESS: _____

MANDATORY MEASURES SPECIFIED
 (Please check boxes below)

Feature or Measure	Yes
SITE DEVELOPMENT (CGC 5.106)	
Storm water pollution control. Newly constructed additions which disturb less than one acre of land shall prevent the pollution of storm water runoff from the construction activities through local ordinance per CGC 5.106.1.1 or Best Management Practices (BMPs) per CGC 5.106.1.2.	<input type="checkbox"/>
Short-Term bicycle parking. If an addition or alteration is anticipated to generate visitor traffic, provide permanently anchored bicycle racks within 200 feet of the visitors' entrance, readily visible to passers-by, for 5 percent of new visitor motorized vehicle parking capacity being added, with a minimum of one two-bike capacity rack. Exception: Additions or alteration which add nine or less visitor vehicular parking spaces. (CGC 5.106.4.1.1.)	<input type="checkbox"/>
Long-Term bicycle parking. For additions or alterations that add 10 or more tenant-occupant vehicular parking spaces, provide secure bicycle parking for 5 percent of the tenant vehicular parking spaces being added, with a minimum of one bicycle parking facility per CGC 5.106.4.1.3.	<input type="checkbox"/>
Bicycle parking facility requirements. Acceptable bicycle parking facility shall be convenient from the street and shall meet additional requirements of CBC 5.106.4.1.5.	<input type="checkbox"/>
Accessible EVCS. When EVSE is installed, accessible EVCS shall be provided in accordance with the California Building Code Section 11B-228.3 per CGC 5.106.5.3.4.	<input type="checkbox"/>
Grading and paving. For additions and alterations that alter the drainage path, construction plans shall indicate how site grading or a drainage system will manage all surface water flows to keep water from entering buildings. Examples of methods to manage surface water include those shown in Items 1-5 per CGC 5.106.10.	<input type="checkbox"/>
ENERGY EFFICIENCY (CGC 5.201)	
California Energy Code. Addition or alteration construction shall meet or exceed the requirements of the 2022 California Building energy efficiency Standards per CGC 5.201.1.	<input type="checkbox"/>
WATER EFFICIENCY AND CONSERVATION	
INDOOR WATER USE (CGC 5.303)	
Meters. Separate submeters or metering devices shall be installed for the uses described in Sections 503.1.1 and 503.1.2.	
Additions in excess of 50,000 square feet. Separate submeters shall be installed as follows:	
1. For each individual leased, rented or other tenant space within the building projected to consume more than 100 gal/day, including but not limited to, spaces used for laundry or cleaners, restaurant or food service, medical or dental office, laboratory, or beauty salon or barber shop.	<input type="checkbox"/>
2. Where separate submeters for individual building tenants are unfeasible, for water supplied to the following subsystems:	<input type="checkbox"/>
a. Makeup water for cooling towers where flow through is greater than 500 gpm.	
b. Makeup water for evaporative coolers greater than 6 gpm.	
c. Steam and hot-water boilers with energy input more than 500,000 Btu/h.	
Excess consumption. A separate submeter or metering device shall be provided for any tenant within an addition that is projected to consume more than 1,000 gal/day.	<input type="checkbox"/>

<p>Water conserving plumbing fixtures and fittings. New plumbing fixtures (water closets and urinals) and fittings (faucets and showerheads) in additions or areas of alterations shall comply with the prescriptive reduced flow rates specified in CGC 5.303.3.1 through 5.303.3.4, per CGC 5.303.5.</p>	<input type="checkbox"/>
<p>Commercial kitchen equipment. Food waste disposers. New disposers in additions and areas of alteration shall either modulate the use of water to no more than 1 gpm when the disposer is not in use (not actively grinding food waste/no-load) or shall automatically shut off after no more than 10 minutes of inactivity. Disposers shall use no more than 8 gpm of water per CGC 5.303.4.1.</p>	<input type="checkbox"/>
<p>Standards for plumbing fixtures and fittings. Plumbing fixtures and fittings shall meet the applicable standards referenced in Table 1701.1 of the 2022 <i>California Plumbing Code</i> and in Chapter 6 of CGC, per CGC 5.303.6.</p>	<input type="checkbox"/>
OUTDOOR WATER USE (CGC 5.304)	
<p>Outdoor potable water use in landscape areas. Nonresidential developments shall comply with the City's Water Service and Use Rules and Regulations, Item No. 24, as adopted in Santa Clara City Code Section 13.15.180, or the California Model Water Efficient Landscape Ordinance (MWELO), whichever is more stringent, per CGC 5.304.1.</p>	<input type="checkbox"/>
WEATHER RESISTANCE AND MOISTURE MANAGEMENT (CGC 5.407)	
<p>Weather protection. Provide a weather-resistant exterior wall and foundation envelope as required by <i>California Building Code</i> Section 1402.2, manufacturer's installation instructions or local ordinance, whichever is more stringent per CGC 5.407.1.</p>	<input type="checkbox"/>
<p>Moisture control. Employ moisture control measures by the following methods:</p> <p style="padding-left: 20px;">Sprinklers. Prevent irrigation spray on structures per CGC 5.407.2.1.</p> <p style="padding-left: 20px;">Entries and openings. Design exterior entries and openings to prevent water intrusion into buildings by providing exterior door protection per CGC 5.407.2.2.1 and flashing per CGC 5.407.2.2.2 (CGC 5.407.2.2).</p>	<input type="checkbox"/> <input type="checkbox"/>
CONSTRUCTION WASTE REDUCTION, DISPOSAL AND RECYCLING (CGC 5.408)	
<p>Construction waste diversion. Recycle and/or salvage for reuse a minimum of 65% of the non-hazardous construction and demolition waste in accordance with Section 5.408.1.1, 5.408.1.2 or 5.408.1.3; or meet a local construction and demolition waste management ordinance, whichever is more stringent (CGC 5.408.1).</p> <p style="padding-left: 20px;">Verification of compliance. A copy of the completed waste management report shall be provided per CGC 5.408.1.4.</p>	<input type="checkbox"/> <input type="checkbox"/>
<p>Universal waste. Additions and alterations to a building or tenant space shall require verification that Universal Waste items are disposed of properly and diverted from landfills per CGC 5.408.2.</p>	<input type="checkbox"/>
<p>Excavated soil and land clearing debris. 100% of trees, stumps, rocks, and associated vegetation and soils resulting primarily from land clearing shall be reused or recycle per CGC 5.408.3.</p>	<input type="checkbox"/>
BUILDING MAINTENANCE AND OPERATION (CGC 5.410)	
<p>Recycling by occupants. Provide readily accessible areas that serve the entire building and are identified for the depositing, storage and collection of nonhazardous materials for recycling per CGC 5.410.1.</p> <p>Additions. All additions conducted within a 12-month period under single or multiple permits, resulting in an increase of 30% or more in floor area, shall provide recycling areas on site per CGC 5.410.1.1.</p>	<input type="checkbox"/> <input type="checkbox"/>
<p>Testing and adjusting. Testing and adjusting of systems shall be required for new systems to serve an addition or alteration per CGC 5.410.4.</p> <p>Testing and adjustment report. After completion of testing, adjusting and HVAC balancing, provide final report of testing signed by the individual responsible for performing these services per CGC 5.410.4.4.</p> <p>Operation and maintenance manual. Provide the building owner with detailed operating and maintenance instructions and copies of guaranties/warranties for each system prior to final inspection per CBC 5.410.4.5.</p> <p>Inspections and reports. Include a copy of all inspection verifications and reports required by the city per CGC 5.410.4.5.1.</p>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>

ENVIRONMENTAL QUALITY	
FIREPLACES (CGC 5.503)	
<p>Install only a direct-vent sealed-combustion gas or sealed wood-burning fireplace, or a sealed woodstove or pellet stove, and refer to residential requirements in the <i>California Energy Code</i>, Title 24, Part 6, Subchapter 7, Section 150. Woodstoves, pellet stoves and fireplaces shall also comply with Santa Clara City Code Chapter 15.65. (CGC 5.503.1)</p> <p>Woodstoves. Woodstoves and pellet stoves shall comply with US EPA New Source Performance Standards (NSPS) emission limits, where applicable, and shall have a permanent label indicating they are certified to meet the emission limits per CGC 5.503.1.1</p>	<input type="checkbox"/>
POLLUTANT CONTROL (CGC 5.504)	
<p>Temporary ventilation. The permanent HVAC system shall only be used during construction if necessary to condition the area of addition or alteration within the required temperature range for material and equipment installation. If the HVAC system is used during construction, use return air filters with a MERV of 8, based on ASHRAE 52.2-1999, or an average efficiency of 30% based on ASHRAE 52.1-1992. Replace all filters immediately prior to occupancy (CGC 5.504.1)</p>	<input type="checkbox"/>
<p>Covering of duct openings and protection of mechanical equipment during construction. At the time of rough installation or during storage on the construction site and until final startup of the heating, cooling and ventilating equipment, all duct and other related air distribution component openings shall be covered with tape, plastic, sheet metal or other methods acceptable to the City to reduce the amount of dust, water, and debris which enter in the system per CGC 5.504.3.</p>	<input type="checkbox"/>
<p>Finish material pollutant control. Finish materials shall comply with Sections 5.504.4.1 through 5.504.4.6.</p> <p>Adhesives, sealants and caulks. Adhesives, sealants and caulks used on the project shall meet the requirements of the standards listed in CGC 5.504.4.1.</p> <p>Paints and coatings. Architectural paints and coatings shall comply with Table 5.504.4.3 unless more stringent local limits apply.</p> <p>Verification. Verification of compliance with this section shall be provided at the request of the City per CGC 5.504.4.3.2.</p> <p>Carpet systems. All carpet installed in the building interior shall meet the testing and product requirements of one of the standards listed in Section 5.504.4.4.</p> <p>Composite wood products. Hardwood plywood, particleboard and medium density fiberboard composite wood products used on the interior or exterior of the building shall meet the requirements for formaldehyde as specified in Table 5.504.4.5.</p> <p>Verification. Verification of compliance with this section shall be provided as requested by the City per CGC 5.504.4.5.3.</p>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
<p>Resilient flooring systems. For 80% of floor area receiving resilient flooring, installed resilient flooring shall comply with CGC 5.504.4.6.</p> <p>Verification. Documentation shall be provided verifying that resilient flooring materials meet the pollutant emission limits per CGC 5.504.4.6.1.</p> <p>Thermal insulation. Thermal insulation shall comply with the requirements of CGC 5.504.4.7.</p> <p>Verification. Documentation shall be provided verifying that thermal insulation materials meet the pollutant emission limits per CGC 5.504.4.7.1.</p> <p>Acoustical ceilings and wall panels. Acoustical ceilings and wall panels shall comply with the requirements of CGC 5.505.4.8.</p> <p>Verification. Documentation shall be provided verifying that acoustical finish materials meet the pollutant emission limits per CGC 5.504.4.8.1.</p>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
<p>Filters. In mechanically ventilated buildings, provide regularly occupied areas of the building with air filtration media for outside and return air prior to occupancy that provides at least a MERV of 13. MERV 13 filters shall be installed after any flush-out or testing and prior to occupancy, and recommendations for maintenance with filters of the same value shall be included in the operation and maintenance manual per CBC 5.504.5.3.</p> <p>Labeling. Installed filters shall be clearly labeled by the manufacturer indicating the MERV rating per CGC 5.504.5.3.1.</p>	<input type="checkbox"/>
<p>Environmental tobacco smoke (ETS) control. Prohibit smoking within 25 feet of building entries, outdoor air intakes and operable windows where outdoor areas are provided for smoking and within the building as already prohibited by other laws, regulations or policies, whichever are more stringent, per CGC 5.504.7.</p>	<input type="checkbox"/>

INDOOR MOISTURE CONTROL (CGC 5.505)	
Indoor moisture control. Building shall meet or exceed the provisions of <i>California Building Code</i> , CCR, Title 24, Part 2, Section 1202 (Ventilation) and Chapter 14 (Exterior Walls). See CGC 5.407.2 for additional measures. (CGC 5.505.1)	<input type="checkbox"/>
AIR QUALITY AND EXHAUST (CGC 5.506)	
Outside air delivery. For mechanically or naturally ventilated spaces in buildings, meet the minimum requirements of Section 120.1 (Requirements For Ventilation) of the <i>California Energy Code</i> or the applicable local code, whichever is more stringent, and Division 1, Chapter 4 of CCR, Title 8, per CGC 5.506.1.	<input type="checkbox"/>
Carbon dioxide (CO₂) monitoring. For buildings equipped with demand control ventilation, CO ₂ sensors and ventilation controls shall be specified and installed in accordance with the requirements of the <i>California Energy Code</i> , CCR, Section 120(c)(4), per CGC 5.506.2.	<input type="checkbox"/>
ENVIRONMENTAL COMFORT (CGC 5.507)	
Acoustical control. Employ building assemblies and components with STC values determined in accordance with ASTM E90 and ASTM E413 or OITC determined in accordance with ASTM E 1332, using either the exterior noise transmission prescriptive or performance method in Sections 5.507.4.1 or 5.507.4.2. (CGC 5.507.4)	<input type="checkbox"/>
Interior sound transmission. Wall and floor-ceiling assemblies separating tenant spaces and tenant spaces and public spaces shall have an STC of at least 40 (CGC 5.507.4.3).	<input type="checkbox"/>
OUTDOOR AIR QUALITY (CGC 5.508)	
Ozone depletion and greenhouse gas reductions. Installation of HVAC, refrigeration and fire suppression equipment shall comply with Sections 5.508.1.1 and 5.508.1.2.	<input type="checkbox"/> As applicable
Supermarket refrigerant leak reduction. New commercial refrigeration systems shall comply with Section 5.508.2 when installed in retail food stores 8,000 square feet or more conditioned area, and that utilize either refrigerated display cases, or walk-in coolers or freezers connected to remote compressor units or condensing units. The leak reduction measures apply to refrigeration systems containing high-global-warming potential (high-GWP) refrigerants with a GWP of 150 or greater.	<input type="checkbox"/> As applicable
INSTALLER AND SPECIAL INSPECTOR QUALIFICATIONS (CGC 702)	
Installer training. HVAC system installers shall be trained and certified in the proper installation of HVAC systems including ducts and equipment by a recognized training or certification program, per CGC 702.1.	<input type="checkbox"/>
Special inspection. Special inspectors employed by the owner or the owner's agent shall be qualified and able to demonstrate competence in the discipline they are inspecting, per CGC 702.2.	<input type="checkbox"/>
VERIFICATION (CGC 703)	
Documentation. Upon request, verification of compliance with the CALGreen code may include construction documents, plans, specifications, builder or installer certification, inspection reports, or other methods acceptable to the building department which will show substantial conformance, per CGC 703.1.	<input type="checkbox"/>

<p>Responsible Designer's Declaration Statement</p> <p>I hereby certify that this project has been designed to meet the requirements of the 2022 California Green Building Standards Code.</p>	<p>Contractor Declaration Statement</p> <p>I hereby certify, as the builder or installer under permit listed herein, that this project will be constructed to meet the requirements of the California Green Building Standards Code.</p>
Name:	Name:
Signature:	Signature:
Date:	Date:
Company:	License:
Address:	Address:
City: State: Zip:	City: State: Zip: